



October 23, 2024

306-551-9412

Via Email: milcal@sasktel.net

Town of Milestone  
Box 74  
Milestone SK S0G 3L0

Attention Waterworks Owner/Operator:

**RE: Precautionary Drinking Water Advisory for *the Town of Milestone*: - Rescinded**

The Water Security Agency (WSA) is satisfied with *two sets of* negative bacteriological sampling and adequate disinfection residuals and turbidity values from samples that have been collected from the water distribution system following fire hydrant replacement causing the system depressurization. Therefore, effective immediately the WSA is rescinding the “**Precautionary Drinking Water Advisory**” for the residents and users of the *Town of Milestone* water supply.

For further information, please do not hesitate to contact the undersigned at 306-551-9412 or rod.broughton@wsask.ca.

Sincerely,

A handwritten signature in black ink, appearing to read "Rod Broughton".

Rod Broughton  
Environment Officer  
Water Security Agency

cc: Derrick Hoehn, Acting Manager, Compliance Promotion South, WSA (email)  
Water Advisories, Water Security Agency  
Saskatchewan Health Authority, Regina Office